

January 20, 2021

Mr. Kyle Craig
Recharge Zone Protection
Edwards Aquifer Authority
900 E Quincy
San Antonio, Texas 78215

Re: 8,000-Gallon Diesel UST
North Central Baptist Hospital
520 Madison Oak Dr, San Antonio, TX

Dear Mr. Craig:

On behalf of North Central Baptist Hospital (NCB) and Tenet Healthcare System (Tenet), Pape-Dawson Engineers, Inc. (Pape-Dawson) is hereby submitting an official request to the Edwards Aquifer Authority (EAA) for a deadline extension regarding a tertiary containment requirement for an approximately 8,000-gallon diesel underground storage tank (UST) located at the North Central Baptist Hospital campus locally addressed at 520 Madison Oak Drive in San Antonio, Bexar County, Texas (hereinafter referred to as Site). The referenced 8,000-gallon UST is used to supply diesel fuel to two (2) 400-gallon aboveground storage tanks (ASTs), which are connected to two (2) emergency backup generators to power hospital operations during an electrical power outage. As indicated in *Chapter 713, Subchapter G (Aboveground and Underground Storage Tanks)*, rule 713.607(c)(1) of EAA Rules, an approved method of tertiary containment must be incorporated into a UST located on the Edwards Aquifer Recharge Zone within 30 years of the date of UST installation. According to EAA and Texas Commission on Environmental Quality (TCEQ) records, the referenced 8,000-gallon UST was installed in March 1991, and as such, is required to have the necessary tertiary containment upgrades implemented by March 27, 2021.

The delay in addressing the above-referenced tertiary containment requirement is largely the result of a change in leadership within the facilities management department at North Central Baptist. Previous discussions to address this issue ended when the facility director resigned at the start of the Coronavirus Disease 2019 (COVID-19) pandemic in early 2020, and hospital leadership was not made aware of the impending deadline until additional notification was received from EAA later that year. Although the COVID-19 pandemic has impeded efforts, hospital administration is committed to resolving this issue.

At this time, Tenet has engaged the services of Pape-Dawson and CDS Muery to aid in regulatory coordination and permitting, and PST system design work, respectively. Plans to bring the existing petroleum storage tank (PST) system at the Site into compliance include the permanent removal of the 8,000-gallon UST from service and installation of a new approximately 12,000-gallon AST in accordance with §713.605 of EAA Rules to meet with emergency backup generator and hospital needs. PST design plans are currently in progress pending regulatory direction. Although PST manufacturing delays associated with COVID-19 plant shutdowns have created a backlog of AST orders, CDS Muery, on behalf

of Tenet, has obtained proposals from at least two (2) vendors with available ASTs. At the time of this reporting, Tenet has approved the purchase of a 12,000-gallon AST by WATCO Tanks, Inc. Expedited fabrication of the referenced tank has also been approved. The timeframe for AST manufacturing is expected to run concurrent with design and regulatory approval of a TCEQ AST Facility Plan.

NCB hospital operations are a vital necessity to the health and wellbeing of the community, and any event impeding operations will have a catastrophic effect on not only the hospital's ability, but also the San Antonio and surrounding area's capacity to fight against the COVID-19 pandemic. Pape-Dawson respectfully requests that the existing UST system at the Site continue to operate until such time that the proposed AST system can be designed, approved, and installed. As a demonstration of North Central Baptist's good regulatory standing, the existing 8,000-gallon UST undergoes monthly vapor monitoring in addition to periodic compliance investigations by the TCEQ. The most recent TCEQ compliance investigation conducted on June 11, 2019 did not identify any violations and referenced no previous violations from past investigations in 2014 and 2016 (Appendix A). Additionally, recent vapor monitoring release detection results from January – December 2020 conducted by Chapman Engineering, Inc. do not indicate the presence of a fuel release from the UST (Appendix B). Recent precision tank tightness testing conducted by Tanknology on January 15, 2021 indicated that North Central Baptist's tank pass tightness criteria (Appendix C).

Introducing a temporary system (i.e., a small PST refilled as needed) at this time would place undue hardship on already exhausted hospital financial resources during this pandemic and uncertainty in PST refueling capabilities on an as-needed basis. Pending AST Facility Plan design and preparation and addressing regulatory comments, Pape-Dawson estimates that the new system will likely be operational as early as December 2021.

We appreciate your prompt attention to this matter. If you have questions or require additional information, please feel free to contact me.

Sincerely,
Pape-Dawson Engineers, Inc.



Heather D. Johnson
Environmental Manager

Attachments:

- Appendix A – 2019 TCEQ Compliance Investigation
- Appendix B – 2020 Vapor Monitoring Release Detection Results
- Appendix C – 2021 Tanknology Precision Tank Tightness Test

APPENDIX A

2019 TCEQ Compliance Investigation

PST_58566_CP_2090611 INVESTIGATION
Texas Commission on Environmental Quality
Investigation Report

The TCEQ is committed to accessibility. If you need assistance in accessing this document, please contact oce@tceq.texas.gov

Customer: VHS San Antonio Partners, LLC

Customer Number: CN601674633

P 06/11/2024

Regulated Entity Name: NORTH CENTRAL BAPTIST HOSPITAL

Regulated Entity Number: RN100629641

Investigation # 1577640

Investigator: CHRISTIAN WENSKE

Conducted: 06/11/2019 -- 06/11/2019

Program(s): PETROLEUM STORAGE TANK REGISTRATION

Investigation Type: Compliance Investigation

Additional ID(s): 58566

Address: 520 MADISON OAK DR,
SAN ANTONIO, TX , 78258

Incident Numbers

Site Classification UNDERGROUND STORAGE
TANK - REGISTRATION

NAIC Code: 622110

SIC Code: 8062

NAIC Code: 62211

NAIC Code: 237310

SIC Code: 1611

Location: REMINGTON DR

Local Unit: EPA PST AUSTIN

Activity Type(s): PSTEACT - PST Energy Act Focused
Investigation

RECEIVED

JAN 09 2020

TCEQ
CENTRAL FILE ROOM

Principal(s):

Role

Name

RESPONDENT

VHS SAN ANTONIO PARTNERS LLC

Contact(s):

Role	Title	Name	Phone
NOTIFIED	LIFE SAFETY OFFICER	MR MARK LUCAS	Work (210) 887-5118
PARTICIPATED IN	LIFE SAFETY OFFICER	MR MARK LUCAS	Work (210) 887-5118
REGULATED ENTITY CONTACT	PLANT OPERATIONS MANAGER	MR MICHAEL SMITH	Work (210) 852-5341
REGULATED ENTITY MAIL CONTACT	PLANT OPERATIONS MANAGER	MR MICHAEL SMITH	Work (210) 852-5341
REGULATED ENTITY CONTACT	LIFE SAFETY OFFICER	MR MARK LUCAS	Work (210) 887-5118
PARTICIPATED IN	PLANT OPERATIONS MANAGER	MR MICHAEL SMITH	Work (210) 852-5341

Other Staff Member(s):

Role	Name
Investigator	PATRICIA MELENDEZ
QA Reviewer	ELIZABETH VANDERWERKEN
QA Reviewer	ROBYN CLAFLIN
Supervisor	KENNETH AUSBIE

Associated Check List

<u>Checklist Name</u>	<u>Unit Name</u>
PST ENERGY ACT FOCUSED INVESTIGATION - revised 12/2014	FIN 58566
PST EPA SOC	FIN 58566

Investigation Comments:**INTRODUCTION:**

On June 11, 2019, Mr. Christian Wenske, Texas Commission on Environmental Quality (TCEQ) Contract Investigator with the University of Texas-Arlington (UTA) Petroleum Storage Tank (PST) Program, conducted a PST Focused Energy Act Investigation at North Central Baptist Hospital located at 520 Madison Oak Dr in San Antonio (Bexar County), Texas.
Facility ID: 58566

On June 4, 2019, the investigator communicated via phone with Mr. Mark Lucas, Life Safety Officer with North Central Baptist Hospital, and scheduled the investigation for June 11, 2019 at 12:00 noon. Mr. Lucas was provided with a list of the compliance documentation requested for the investigation.

During the inspection, Mr. Lucas and Mr. Michael Smith, Plant Operations Manager with North Central Baptist Hospital, were on site with the investigator.

GENERAL FACILITY AND PROCESS INFORMATION:

The facility operates as an emergency generator facility.

According to TCEQ's Permit and Registration Information System (PARIS), the regulated entity consists of one (1) Underground Storage Tank (UST) that was installed on March 1, 1991. The UST is registered as a double-walled, Fiberglass-Reinforced Plastic (FRP) tank.

Tank 1 has the capacity of 8,000 gallons and stores diesel fuel.

All product lines are registered as double-walled, steel, pressurized lines, but they are actually FRP lines.

REGISTRATION:

One UST is currently registered and self-certified with the TCEQ.

The piping is registered as steel, but is actually FRP.

The regulated entity has been requested to make the necessary amendments to the TCEQ Registration and Self Certification Form for this facility.

BACKGROUND:

On November 4, 2016, Ms. Deeandrea Burgos, TCEQ Contract Investigator, with the UTA PST Program conducted a PST Focused Energy Act Investigation at the above-referenced facility. No violations were documented as a result of this investigation. (CCEDS Investigation 1371712)

On June 18, 2014, Mr. Marc Geraci with the UTA PST Program (TCEQ Contractor) conducted a PST Focused

Energy Act investigation at the above-referenced facility. No violations were documented as a result of this investigation. (CCEDS Investigation 1186153)

ADDITIONAL INFORMATION:

During the on-site investigation and review of the facility's records, the following findings were determined:

MONTHLY THROUGHPUT:

According to the documentation provided by Mr. Smith during the on-site investigation, the average monthly throughput over a twelve month period was less than 1,000 gallons. This facility is considered a minor facility because the throughput is less than 50,000 gallons per month.

DELIVERY CERTIFICATE:

The TCEQ Delivery Certificate has an expiration date of January 31, 2020, and was posted at the facility. One UST was included on the Delivery Certificate.

FINANCIAL ASSURANCE:

Financial Assurance mechanism utilized by this UST system is insurance provided by Admiral Insurance Company. This insurance company has issued liability insurance for taking corrective action and compensating third parties for bodily injury and property damage caused by accidental releases. The limits of liability are \$1,000,000 per occurrence and \$3,000,000 annual aggregate arising from operating the underground storage tank included in the policy. The policy is effective as of June 1, 2019 and will expire on June 1, 2020. One UST is included in this insurance policy.

CORROSION PROTECTION:

During the on-site investigation, Mr. Smith submitted a Cathodic Protection Tank Verification Survey conducted on July 18, 2014 by Chapman Engineering. According to the report, the tank was indicated as being a Fiberglass tank and not in need of cathodic protection. The product piping was found to be Fiberglass-Reinforced Plastic (FRP) piping.

TANK MONTHLY RELEASE DETECTION:

Tank release detection is provided by Vapor Monitoring.

During the on-site investigation, Mr. Smith submitted Vapor Monitoring reports for the tank (and piping). The passing periods reviewed were from June 2018 to May 2019.

PIPING RELEASE DETECTION:

-Pressurized Piping:

The regulated entity has mechanical Line Leak Detectors (LLDs) installed on the UST.

During the on-site investigation, Mr. Smith provided an annual line tightness and LLD test conducted by Tanknology on October 29, 2018. The lines and LLDs had passing results.

The piping is also covered for release detection by the Vapor Monitoring mentioned above.

SPILL AND OVERFILL:

Each tank was equipped with a tight-fill fitting.

One spill bucket was installed. The investigator documented that the spill bucket was maintained in good operating condition; free of visible cracks or damage that would prevent them from being liquid tight.

6/11/2019 Inv. # - 1577640

Page 4 of 4

The regulated entity provided overfill verification during a previous investigation. Investigation 1371712 indicates that the tank is equipped with a ball float as its overfill protection.

SUSPECTED OR CONFIRMED RELEASES:

The investigator found no evidence of a suspected or confirmed release as a result of this investigation.

OPERATOR TRAINING:

Mr. Michael Smith received the Class A/B Operator Training Certificate on February 16, 2017 from PASS. The training certification will expire on February 16, 2020. The investigator observed the Class C Operator training records for all of the employees on-site.

CONCLUSION:

No violations were documented during this investigation. A General Compliance (GC) letter has been issued as a result of this investigation and will be sent to Mr. Michael Smith.

Attachments:

1. Focused Checklist
2. Site Diagram
3. Old CP Test
4. Photographs

No Violations Associated to this Investigation

Signed **Christian Wenske**
Digitally signed by Christian Wenske
Date: 2019.07.18 12:54:37 -05'00'
Environmental Investigator

Date _____

Signed 
Supervisor

Date JUN 27 2019**Attachments: (in order of final report submittal)**☐ Enforcement Action Request (EAR)☒ Letter to Facility (specify type) : **focused**☐ Investigation Report☐ Sample Analysis Results☐ Manifests☐ Notice of Registration☐ Maps, Plans, Sketches☐ Photographs☐ Correspondence from the facility☐ Other (specify) : _____

June 27, 2019



THE UNIVERSITY

OF TEXAS

AT ARLINGTON

Center for
Environmental
Excellence

Division for
Enterprise Development

1851 Crosspoint,

Suite 1270

Houston, Texas 78759

T (512) 904-2281

F (512) 904-2288

Mr. Michael Smith, Plant Operations Manager
San Antonio Partners LLC
1150 Brussels St
San Antonio, Texas 78219

Re: Petroleum Storage Tank (PST) Focused Energy Act Investigation for Release Detection, Corrosion Protection, Financial Assurance, Spill Containment and Overfill Prevention, and Delivery Certificate at: North Central Baptist Hospital, 520 Madison Oak Dr, San Antonio (Bexar County), Texas 78258
TCEQ PST Registration No.: 58566 RN: 100629641

Dear Mr. Smith:


On June 11, 2019, Mr. Christian Wenske of University of Texas at Arlington (UTA) Austin office, PST Program Contractor for the Texas Commission on Environmental Quality (TCEQ), conducted an investigation of the above-referenced facility to evaluate compliance with certain applicable requirements for the PST program. No violations are being alleged as a result of the investigation.

Please note that this investigation was limited in scope. Your facility is still required to comply with all requirements of 30 Texas Administrative Code (TAC), Chapter 334, and, under the Energy Policy Act of 2005, is subject to compliance investigations every three years.

If you feel that your facility may require assistance to achieve compliance with the requirements of the PST program, you have several options:

- Refer to the PST rules found in Title 30 TAC, Chapter 334, located at:
<http://www.tceq.state.tx.us/rules/indxpdf.html#334>;
- Refer to the TCEQ's newest Underground Storage Tank Compliance Tool: The PST Super Guide: A Comprehensive Guide to Compliance in Texas (RG-475) located at:
http://www.tceq.state.tx.us/comm_exec/forms_pubs/pubs/rg/rg-475/
- Hire a contractor who is knowledgeable with PST issues to assist you with regulatory compliance;
- Refer to the Small Business and Local Government Assistance (SBLGA) website at: www.sblga.info – click on the link for Petroleum Storage Tanks; or
- Call the SBLGA free, confidential compliance assistance hotline at 1-800-447-2827.

The TCEQ appreciates your assistance in this matter and your compliance efforts to ensure protection of the State's environment.

Sincerely,


Mr. Kenneth Ausbie, PST Team Manager
University of Texas / Arlington (TCEQ Contractor)

KA/CW/cw

Initials: CW

☒ **Compliant**
☐ **Non-Compliant**

☐ GPS File: _____

Region: 13

**UTA CENTER FOR ENVIRONMENTAL EXCELLENCE
PST FOCUSED ENERGY ACT INVESTIGATION CHECKLIST
FOR THE TCEQ**

Notification Date: 06/04/19
☒ Phone ☐ fax ☐ e-mail
☐ Other: _____

Start Time: 11:20
End Time: 12:15

CCEDS: _____ By: _____

1577640

Investigation Date: 06/11/19 Facility Thru-Put monthly avg. <1000 gal(s) for all tanks over 12 month(s)

Facility ID: 58566 Facility RN Name: NORTH CENTRAL BAPTIST HOSPITAL RN # RN100629641

Facility Address: 520 MADISON OAK DR City: SAN ANTONIO Zip Code: 78258 County: BEXAR

Owner: VHS SAN ANTONIO PARTNERS LLC Phone # (210) 887-5118 CN # CN601674633

Owner Address: 1150 BRUSSELS ST City: SAN ANTONIO Zip Code: 78219

Operator: Same as Owner Phone # _____ CN # _____

Operator Address: Same as Owner City: _____ Zip Code: _____

Facility Phone # (210) 887-5118 # of Tanks: 1 Tank Material: FRP Tanks: DW

Capacity of Tanks: 1 8K D _____ _____ _____ _____ Piping Material: Steel (actually FRP) Piping: DW

Tanks Contain: ☐ gasoline ☒ diesel ☐ other: 3/1/1991 Facility Type: ☐ retail ☐ fleet refueling ☒ other: Emergency Generator

Investigator	Christian Wenske						*OS = Present on-site (checkmark = yes)
Name	*OS	*Role	Title	Organization	Address		Phone
Mark Lucas	<input checked="" type="checkbox"/>	N, P, REC	Life Safety Officer	NORTH CENTRAL BAPTIST HOSPIT	See Facility		(210) 887-5118
Micheal Smith	<input checked="" type="checkbox"/>	P, REC, REMC	Plant Operations Manager	NORTH CENTRAL BAPTIST HOSPIT	See Owner and Facility		(210) 852-5341
	<input type="checkbox"/>						
	<input type="checkbox"/>						
	<input type="checkbox"/>						

*Role: Notified (N), Participated in (P); Regulated Entity Contact (REC), Regulated Entity Mail Contact (REMC) (must have REC and REMC)

#	SELF CERTIFICATION Requirement	Investigator Notes	Compliant	Citation
1	Does the owner/operator have a current delivery certificate? <input type="checkbox"/> Requested <input type="checkbox"/> Submitted: _____ (MM/DD/YYYY)	<input checked="" type="checkbox"/> A Central Registry Query indicates the facility is self-certified. The delivery certificate is current with an expiration date of _____ (MM/YYYY). <input type="checkbox"/> The delivery certificate has expired. The expiration date of _____ (MM/YYYY). - # _____ fuel drops over _____ month(s) Notes: <div style="border: 1px solid black; height: 40px; width: 100%;"></div> <input type="checkbox"/> Common Carrier violation cited effective April 19, 2012? (attach checklist)	Yes	334.8(c) (5)(A)(i) – failure to have a current, valid certificate (expired).

UTA CENTER FOR ENVIRONMENTAL EXCELLENCE
PST FOCUSED ENERGY ACT INVESTIGATION CHECKLIST
FOR THE TCEQ

#	FINANCIAL ASSURANCE Requirement	Investigator Notes	Compliant	Citation
2	<p>Can the facility demonstrate financial responsibility for taking corrective action and for compensating third parties for bodily injury and property damage caused by accidental releases?</p> <p><input type="checkbox"/> Requested <input checked="" type="checkbox"/> Submitted: _____ (MM/DD/YYYY)</p>	<p><input checked="" type="checkbox"/> Financial assurance is provided by:</p> <p>Name of company: _____ Admiral Insurance Company</p> <p>Date of policy: 6/1/2019 - 6/1/2020</p> <p>Policy # \$1M/\$3M</p> <p><input type="checkbox"/> Financial assurance was provided by self insurance in the form of a: _____ Select</p> <p><input type="checkbox"/> Facility does not and could not provide financial assurance.</p> <p><input type="checkbox"/> Records not available for review.</p> <p>Notes: _____ _____</p>	Yes	<p>37.815(a) and 37.815(b) – failure to provide proof of financial assurance (insurance).</p>
#	CORROSION PROTECTION Requirement	Investigator Notes	Compliant	Citation
3	<p>Is the System equipped with a corrosion protection system and complying with the requirements to ensure that releases due to corrosion are prevented?</p> <p><input type="checkbox"/> Requested <input checked="" type="checkbox"/> Submitted: _____ (MM/DD/YYYY)</p>	<p>Tanks:</p> <p><input type="checkbox"/> Impressed Current System (Steel Tanks)</p> <p>- Rectifier appears to be on: Select Appears to be <u>working</u> : Select</p> <p>*60 day checks conducted: Select</p> <p>- *Three year test conducted : Select (see/fill below)</p> <p><input type="checkbox"/> Sacrificial/Galvanic System (Steel w/FRP)</p> <p>- Sacrificial (galvanic) anodes <u>present</u>? Select</p> <p>- Anodes appear to be <u>functioning</u>? Select</p> <p>- *Three year test conducted : Select (see/fill below)</p> <p><input checked="" type="checkbox"/> Electrically Isolated in the form of:</p> <p><input type="checkbox"/> Composite Tank (Steel w/FRP)</p> <p>- 100 mil FRP thickness? Select</p> <p><input type="checkbox"/> Jacketed Tanks</p> <p><input checked="" type="checkbox"/> Fiberglass Tanks</p> <p><input type="checkbox"/> Dual Protected (both ACT 100 and STI-P3)</p> <p>- Tank Type: _____</p> <p>- *CP test conducted? Select</p> <p>Date: 7/18/14 (MM/DD/YYYY); (NACE#) 23357</p> <p>Co. Chapman Engineering</p> <p>Piping:</p> <p><input checked="" type="checkbox"/> Electrically isolated in the form of:</p> <p><input checked="" type="checkbox"/> Fiberglass Piping</p> <p><input type="checkbox"/> Flexible Piping</p> <p><input type="checkbox"/> Impressed current system (Steel Piping see/fill above)</p> <p><input type="checkbox"/> Sacrificial/Galvanic System (Steel Piping see/fill above)</p> <p><input type="checkbox"/> Facility did not have corrosion protection.</p> <p><input type="checkbox"/> Records not available for review.</p> <p>Notes: _____ _____</p>	Yes	<p>334.49(a)(1) – failure to have corrosion protection for the UST system.</p>

**UTA CENTER FOR ENVIRONMENTAL EXCELLENCE
PST FOCUSED ENERGY ACT INVESTIGATION CHECKLIST
FOR THE TCEQ**

#	RELEASE DETECTION Requirement	Investigator Notes	Compliant	Citation
4	<p>Are the tanks monitored in a manner that will detect release at least monthly?</p> <p><input type="checkbox"/> Requested <input type="checkbox"/> Submitted: _____ (MM/DD/YYYY)</p>	<p><input type="checkbox"/> ATG and Inventory Control (IC) (must have both)</p> <p>- IC reviewed months: _____ to _____.</p> <p>- Monthly ATG tank tests (1 pass, per tank, per month) reviewed months: _____ to _____.</p> <p><input type="checkbox"/> Statistical Inventory Reconciliation (SIR) and IC</p> <p>- SIR reviewed months: _____ to _____ by _____</p> <p>(Name of SIR company).</p> <p><input type="checkbox"/> Interstitial Monitoring</p> <p>- Reviewed months: _____ to _____.</p> <p><input checked="" type="checkbox"/> Vapor Monitoring or <input type="checkbox"/> Groundwater Monitoring</p> <p>- Reviewed months: 06/2018 to 05/2019 by Chapman Engineering</p> <p>(Name of testing company). *Site Assessment conducted? Select</p> <p><input type="checkbox"/> Other:</p> <p><input type="checkbox"/> Manual Monitoring (tanks < 1,000 gallons only)</p> <p><input type="checkbox"/> Monthly Monitoring (emergency generators only)</p> <p><input type="checkbox"/> Monitoring of Secondary Containment Barriers</p> <p>- Reviewed months: _____ to _____.</p> <p><input type="checkbox"/> Facility did not have tank release detection.</p> <p><input type="checkbox"/> Records not available for review.</p> <p>Notes:</p> <div style="border: 1px solid black; height: 50px; width: 100%;"></div>	Yes	<div style="border: 1px solid black; padding: 5px; margin-bottom: 10px;"> <p>ATG found?</p> <p>Yes</p> </div> <p>334.50(b)(1)(A) – failure to have release detection for UST systems.</p>
5	<p>Is the piping monitored in a manner to detect a release from any portion of the piping system?</p> <p><input type="checkbox"/> Requested <input type="checkbox"/> Submitted: _____ (MM/DD/YYYY)</p>	<p><input checked="" type="checkbox"/> Pressured or <input type="checkbox"/> Suction or <input type="checkbox"/> Gravity lines</p> <p><input checked="" type="checkbox"/> Line Leak Detector present? Yes</p> <p><input checked="" type="checkbox"/> Mechanical LLD <input type="checkbox"/> Electronic LLD</p> <p><input checked="" type="checkbox"/> Line Tightness Test or <input type="checkbox"/> N/A (electronic LLD, Suction)</p> <p><input checked="" type="checkbox"/> Annual <input type="checkbox"/> Triennial</p> <p>- Test successfully conducted on 10/29/18 (MM/DD/YYYY) by Tanknology</p> <p>(Name of testing company).</p> <p>*LLD Tested? Yes (see/fill above)</p> <p><input type="checkbox"/> Monthly Monitoring (electronic LLD only)</p> <p>- Reviewed months: _____ to _____.</p> <p><input checked="" type="checkbox"/> Other Monitoring: Vapor Monitoring (see/fill section #4)</p> <p><input type="checkbox"/> Facility did not have release detection for the piping.</p> <p><input type="checkbox"/> Records not available for review.</p> <p>Notes:</p> <div style="border: 1px solid black; height: 50px; width: 100%;"></div>	Yes	<p>334.50(b) (2) – failure to provide proper release detection for the piping associated UST systems.</p>

UTA CENTER FOR ENVIRONMENTAL EXCELLENCE
PST FOCUSED ENERGY ACT INVESTIGATION CHECKLIST
FOR THE TCEQ

#	SPILL CONTAINMENT & OVERFILL PREVENTION Requirement	Investigator Notes	Compliant	Citation
6	Was the UST system equipped with spill and overfill prevention equipment that is functional? <input type="checkbox"/> Requested <input type="checkbox"/> Submitted: _____ (MM/DD/YYYY)	<input checked="" type="checkbox"/> Auto flow restrictor valve (Ball-float) <input type="checkbox"/> Automatic shut-off valve (flapper) <input type="checkbox"/> Facility has no spill and no overfill prevention equipment. <input type="checkbox"/> Records not available for review (ball-floats) Notes: <div style="border: 1px solid black; padding: 5px; margin-top: 5px;">See CCEDS Investigation 1371712</div>	Yes	334.51(b) (2) – failure to equip all USTs with spill and overfill prevention equipment.
7	RELEASE REPORTING Requirement If there was any suspected release, was it reported and investigated? <input type="checkbox"/> Requested <input type="checkbox"/> Submitted: _____ (MM/DD/YYYY)	Investigators Notes N/A Notes: <div style="border: 1px solid black; height: 40px; margin-top: 5px;"></div>	N/A	334.74 – failure to conduct release investigation and confirmation steps within 30 days of discovery of suspected release.
8	RECORD Requirement Is the facility maintaining records to allow the investigator to perform regulatory oversight and/or determine compliance status?	Investigators Notes Facility maintained records for compliance status. Investigator not able to review records. Facility failed to keep required and legal copies of the following documents (please specify): <input type="checkbox"/> Release Detection Tanks: _____ <input type="checkbox"/> Release Detection Piping: _____ <input type="checkbox"/> Corrosion Protection: _____ <input type="checkbox"/> Overfill: ball float verification for: _____ <input type="checkbox"/> Financial Assurance: _____ <input type="checkbox"/> Other: _____ <input type="checkbox"/> Other: _____	Yes	334.10 (b)(1)(B) – failure to maintain legible copies of all required records pertaining to an UST system in a secure location on the premises of the facility, immediately available for inspection by Commission personnel.

Communication History:

Date: 6/4/2019	Name: Mark Lucas	Type: Phone/Notify
Date: _____	Name: _____	Type: _____
Date: _____	Name: _____	Type: _____
Date: _____	Name: _____	Type: _____

Documentation/Photographs Attached:

1. Site Diagram _____
2. Old CP Test _____
3. Photographs _____
4. _____
5. _____

Notes: Operator Training Present? ☒ Name: Michael Smith From: PASS Date: 2/16/2017

Has Class C Operators _____

Issues for Attention of Regional Office:

The piping is registered as steel but is actually FRP.

<input checked="" type="checkbox"/> Final review of checklist conducted before signing. <input checked="" type="checkbox"/> File uploaded into DED.	Investigator Signature: <u>Christian Wenske</u> <div style="font-size: small; text-align: right;">Digitally signed by Christian Wenske Date: 2019.06.26 08:05:12 -0500</div>
--	--

UTA CENTER FOR ENVIRONMENTAL EXCELLENCE
PST FOCUSED ENERGY ACT INVESTIGATION CHECKLIST
FOR THE TCEQ

Focused Investigation Additional Notes

Facility ID: **58566**

1) Self-Certification Notes:

2) Financial Assurance Notes:

3) Corrosion Protection Notes:

4) Release Detection for Tanks Notes:

5) Release Detection for Piping Notes:

6) Spill and Overfill Notes:

7) Suspected Releases Notes:

8) Records Request Notes:

9) Other (Please specify):

10) Communication History cont:

SIGNIFICANT OPERATIONAL COMPLIANCE (SOC) CHECKLIST

Regulated Entity Name: NORTH CENTRAL BAPTIST H

Date: 06/11/19

Additional ID 58566

Investigator Name Christian Wenske

Item No.	Description	Notes
A RELEASE PREVENTION COMPLIANCE MEASURES MATRIX		
	1 Spill Prevention device is present and functional?	Yes
	2 Overfill prevention device is present and operational?	Yes
	3 Repaired USTs and piping were tightness tested within 30 days of repair completion (not required with internal inspection or if monthly monitoring is used).	N/A
	4 Cathodic protection system was tested/inspected within 6 months of repair of any cathodically protected UST system.	N/A
	5 Corrosion protection system is properly operated and maintained to provide continuous protection.	Yes
	6 UST systems with impressed current cathodic protection are inspected every 60 days.	N/A
	7 Lined USTs are inspected periodically and lining is in compliance	N/A
	8 Buried metal UST and piping components are isolated from the soil or cathodically protected.	Yes
A9	Is the Facility SOC with release prevention (If ANY of the answers in this section are "NO", this answer must be "NO").	Yes
B RELEASE DETECTION COMPLIANCE MEASURES MATRIX		
	1 Release detection method is present	Yes
	2 Release detection system is operating properly (able to detect a release from any portion of system that routinely contains product)	Yes
	3 Release detection meets performance standards in 40 CFR 280.43 or 40 CFR 280.44 (30 TAC 334.50)	Yes
	4 TCEQ has been notified of a suspected release as required (if applicable)	N/A
	5 USTs and piping are monitored monthly for releases and records are available	Yes
	6 Hazardous substance UST system leak detection meets requirements in 40 CFR 280.42(b) (from 40 CFR 280.12: Hazardous substance UST system means an underground storage tank system that contains a hazardous substance defined in section 101(14) of the Comprehensive Environmental Response, Compensation and Liability Act of 1980 (but not including any substance regulated as a hazardous waste under subtitle C) or any mixture of such substances and petroleum, and which is not a petroleum UST system)	N/A
	7 FOR TEMPORARY CLOSURE: Release detection requirements are being met for UST systems containing product (40 CFR 280.70(A)?	N/A
B8	Facility is SOC with release detection (if ANY of the above answers in this section are "NO", this answer MUST be "NO")	Yes
C OVERALL SOC		
C1	Facility is SOC (IF EITHER A9 or B8 answers are "NO", this answer MUST be "NO")	Yes

SITE DIAGRAM

Facility Name: North Central Baptist Hospital

Facility ID: 58566

Date

6/11/2019

Investigator

Christian Wenske



UNIVERSITY OF

TEXAS

ARLINGTON

Division for Enterprise Development

Madison Oaks

Hospital



Diesel

The University of Texas at Arlington

Center for Environmental Excellence

Additional Notes:

Not to Scale. This drawing is part of the inspection checklist.



July 18, 2014

CORPORATE OFFICE:
P. O. Box 1305
Boerne, TX 78006

Mr. Jim Rockey
North Central Baptist Hospital
520 Madison Oak Drive
San Antonio, Texas 78025

**Underground Storage Tank Piping Evaluation
520 Madison Oak Drive, San Antonio, Texas
TCEQ Facility ID #58566**

Dear Mr. Rockey:

Based on rule requirements through the Texas Commission on Environmental Quality (TCEQ), Chapman Engineering personnel evaluated the underground piping, which is part of the existing fuel system at North Central Baptist Hospital in San Antonio. This system consists of 1 - 8,000-gallon fiberglass-reinforced plastic (FRP) underground storage tank (UST). The tank supplies diesel fuel to the emergency generator system for the hospital.


Mr. Derek Moellendorf, NACE CP Tester for our company, has inspected the submersible pump location and has photographs of the fuel lines in that pump containment enclosure. The photos clearly show that fiberglass-reinforced plastic (FRP) piping exits the containment enclosure, and then carries fuel feeding to the generator location, along with fuel "return" and vent line from that location.


Piping is double-walled, as indicated by the "clam-shell" fittings used to join the fiberglass piping sets within the containment.

Because the piping is made of FRP, and no metal piping is in contact with soil or water within the containment or in the pipe runs through soil or backfill, there is no regulatory requirement for North Central Baptist Hospital to protect the product lines from external corrosion.

Thank you for this opportunity to provide this letter report. For questions or comments, please contact us at (830)-816-3311.

Sincerely,



Derek Moellendorf
NACE CP Tester #18337
CC/dm


Cal Chapman, P. E.
NACE CP Specialist



UTA PHOTOGRAPHIC DOCUMENTATION

Facility ID No.:	58566	Regulated Entity:	North Central Baptist Hospital		
Investigation Date:	6/11/2019	Photographer:	Christian Wenske	County:	Bexar



SUBJECT: Delivery Certificate

COMMENTS: The Delivery Certificate expires at the end of January 2020.

PHOTO # 1



SUBJECT: Spill Bucket

COMMENTS: The spill bucket is clean.

PHOTO # 2

UTA PS. PHOTOGRAPHIC DOCUMENTATION

Facility ID No.:	58566	Regulated Entity:	North Central Baptist Hospital		
Investigation Date:	6/11/2019	Photographer:	Christian Wenske	County:	Bexar



SUBJECT: Sump

COMMENTS: A mechanical line leak detector is present.

PHOTO # 3

APPENDIX B
2020 Vapor Monitoring
Release Detection Results



CHAPMAN ENGINEERING, INC.

Fuel Finder™ 30-Day Vapor Monitoring Release Detection Results

Customer:

North Central Baptist
520 Madison Oak
San Antonio, Texas 78258

Location:

North Central Baptist Hospital
520 Madison Oak
San Antonio, Texas 78258

Service Period:**December, 2020**

TCEQ Owner ID#:

60661

TCEQ Facility ID#:

58566

CE Route #:

14

YEAR: 2020

MONTH	DIESEL
January	P
February	P
March	P
April	P
May	P
June	P
July	P
August	P
September	P
October	P
November	P
December	P

Legend: P = Pass F = Fail I = Inconclusive

30-Day Release Detection: PASS

REGULATORS and/or INSURANCE COPY: Please retain this report in your files onsite. In the event of an inspection by TCEQ, you should have Release Detection Reports available for the previous 12 months.

Should you have any questions regarding this report, do not hesitate to contact our office at 800-375-7747.

Thank you for your business.

Cal Chapman P. E.
President

APPENDIX C
2021 Tanknology Precision
Tank Tightness Test

Technician: Christopher Brown
Technician Certification: (See forms)



VacuTect
Tank Tightness Test


page 1 of 1

Work Order: 5216702 Date: 1/15/2021
Site Name/ID: North Central Baptist Hospital
Address: 520 MADISON OAK
City: San Antonio State: TX Zip: 78258

Tank Information	1 Diesel					
Customer Tank ID	1					
Regulatory Tank ID	1					
Product Category	Diesel					
Product Name	Diesel					
Gallons Capacity	8000					
Tank Type	Fiberglass					
Tank Walls	Doublewall (factory)					
Compartmentalized	No					
Siphon Tank	No					
Vents included with test	not tested					
Test Start Time	09:59:00					
Test End Time	11:07:00					
Water ingress (Y/N)	No					
Bubble ingress (Y/N)	No					
Ullage ingress (Y/N)	No					
Test Result (P/F/I)	Pass					

☒ Yes ☐ No diagnostic only - Test was performed per 3rd party certifications as specified in 40 CFR parts 280 and 281.

Technician Comments :

Technician Name Christopher Brown Certification # 144548
Technician Signature 

Environmental Compliance for Petroleum Systems
©2021 Tanknology Inc., Austin, TX. All rights reserved. tanknology.com



Site Diagram

(This site diagram is for reference only and is not drawn to scale)

Work Order: 5216702
Site ID / Name: NORTH CENTRAL / North Central Baptist Hospital
Address: 520 MADISON OAK
City: San Antonio State: TX Zip: 78258

